

**Addendum No. 2**  
**May 30, 2024**

Project: Harrisburg Softball / Baseball Complex  
Harrisburg, South Dakota  
Architecture Incorporated Project #2822

Architect: Architecture Incorporated

Letting: **Tuesday, June 4, 2024**  
**2:00 p.m.**

Location: Community Center Conference Room at the Harrisburg School District Administration Offices, 200 Willow Street, Harrisburg, South Dakota 57032. (Enter from southeast community center entrance).

Scope of this Addendum:

To all bidders and all others to whom drawings and specifications have been issued by Architecture Incorporated, this Addendum forms a part of the Contract Documents. Acknowledge receipt of this addendum by listing its number and date in the bidder's Form of Proposal. Failure to do so may subject bidder to disqualification. This addendum modifies the drawings and specifications as follows:

**GENERAL ITEMS:**

1) **SECTION 011000 – SUMMARY – DONATED WORK ITEMS**

- a) 1.5.A Donated Work Items: Omit all references to donated concrete materials delivered to the site by Knife River Ready Mix, Sioux Falls, SD. **There will be no donated materials.** The Contractor shall include the cost of all concrete materials delivered to the site in the bid and in the scope of work. The Contractor can obtain concrete from any qualified ready-mix plant that meets the specifications.

2) **SECTION 334100 – STORM UTILITY DRAINAGE PIPING**

- a) Storm Sewer Piping Clarification(s):
  - i) Perforated storm sewer piping shall be HDPE N-12 dual wall pipe with soil tight joints.
  - ii) Non-perforated storm sewer piping shall be HDPE N-12 dual wall with soil tight joints, HP Storm, or approved equal. Single wall corrugated HDPE pipe will not be allowed.

**GENERAL APPROVALS:**

The following material or equipment furnished by the manufacturers listed, may be substituted as equivalent providing that each item, material, and piece of equipment conforms to the design and requirement of the specifications.

<u>SHEET</u>	<u>ITEM</u>	<u>MANUFACTURER</u>
9.30	Exterior Lighting Type AA, AA2 Type BB	Gardco WE-EF

**END OF ADDENDUM No. 2**